

GRATI POWER GENERATOR AND O&M SERVICE UNIT

Tanggal

2026-08-10

NO	PARAMETER		SATUAN	OPERASI (minimal 20 menit)	
				sebelum start	sesudah start
1	Waktu Pencatatan			09.00	09.25
2	Oil Pressure		Kg/Cm	5	5
3	Oil Temperature		C	50	60
4	Water Temperature		C	50	70
5	Speed		Rpm	1600	1600
6	Hour Meter	1	H	16.2	16.4
		2	H	-	-
7	Main Line	Voltage	V	400	400
		Frequency	Hz	50	50
8	Generator	Breaker	Open / Close	Open	Open
		Voltage	Hz	400	420
		Frequency	Hz	50	50
9	Load Current		A	0	0
10	Daya		KW	0	0
11	COS			1	1
12	Battery Charge Voltage		V	26	27
13	Hour		N	51.2.1	51.2.2
14	Lube Oil Level		N	Normal	Normal
15	Accu Level		N	Normal	Normal
16	Radiator Level		N	Normal	Normal
17	Fuel Oil Level		N	Normal	Normal

Keterangan : L : Low N : Normal H : Hight F : Full

Catatan : start dai lokal

SHIFT

K3

OPERATOR

SUPERVISOR

SHIFT-A			
	Firdaus	Andrian	Dani C