

GRATI POWER GENERATOR AND O&M SERVICE UNIT

Tanggal

2026-08-05

NO	PARAMETER		SATUAN	OPERASI (minimal 20 menit)	
				sebelum start	sesudah start
1	Waktu Pencatatan			08:45	09:00
2	Oil Pressure		Bar	6.45	6.45
3	Fuel Pressure		Bar	1.76	1.76
4	Fuel Temperature		C	31	31
5	Coolant Pressure		Bar	2.00	2.00
6	Coolant Temperature		C	44	44
7	Speed		Rpm	1501	1501
8	Inlent Temperature		C	38	38
9	Turbo Pressure		Bar	1.13	1.13
10	Generator	Breaker	Open / Close	Open	Open
		Voltage	V	230	230
		Frequency	Hz	50.1	50.1
		Current	A	150	150
11	Load		KW	29	29
12	Battery Charge Voltage		V	27.9	27.9
13	Lube Oil Level		N	Normal	Normal
14	Accu Level		N	Normal	Normal
15	Radiator Level		N	Normal	Normal
16	Fuel Oil Level		N	Normal	Normal

Keterangan : L : Low N : Normal H : Hight F : Full

Catatan : -

SHIFT

K3

OPERATOR

SUPERVISOR

SHIFT-B			
	Firsya	Taufik	Didik H